

# GOVT. MODEL HIGH SCHOOL

MALOYA-II, CHANDIGARH

Email: gmhsmaloya2@gmail.com

Contact no: 0172-2617037

TO

THE MEDICAL OFFICER OF HEALTH  
MUNICIPAL CORPORATION  
30 BAYS BUILDING SECTOR 17 B  
CHANDIGARH

Memo no. GMHS/MALOYA II/2024/42  
Dated Chandigarh, the 19/4/24

**Subject: Regarding "HEALTH AND SANITARY CONDITION" certificate in R/o GMHS MALOYA II Chandigarh.**

With reference to subject cited above you are informed that our school require HEALTH AND SANITARY CONDITION certificate for CBSE affiliation. Maximum work regarding sanitation is completed some works are under process. You are requested to provide the Health and Sanitation certificate to school. This certificate is required on urgent basis.

*Handwritten signature*

*Handwritten signature*  
Headmaster  
Govt. Model High School  
Maloya-II, Chandigarh (U.T.)

*S*  
19/4/24



# MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

## TEST - REPORT


Not for legal use

Ref. No. & Date :- No GMHS/ Maloya-II/2024/533 dated 05.03.2024  
Issued to :- The Headmaster  
:- Govt. Model High School  
:- Maloya - II, Chandigarh  
Quantity of sample :- Approximate 1200 ml.  
Date of Collection :- 13-04-2024  
Client reference :- Sample Collected by Laboratory Staff  
Packing of sample :- Sample filled in P.P. and Glass Bottle  
Source of sample :- from School tap of Govt. Model High School  
Maloya - II, Chandigarh

S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.48
2	Odour	Agreeable	----	Agreeable
3	Taste	Agreeable	----	Agreeable
4	Turbidity	< 1.0	mg/l	0.6
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO <sub>3</sub> )	< 200	mg/l	128
7	Total Hardness (as CaCO <sub>3</sub> )	< 200	mg/l	92
8	Chloride (as Cl)	< 250	mg/l	4
9	Free & Saline Ammonia	Nil	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	168
11	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No.04/2024-25/187392, dated 12.04.2024, Amount Rs.3300/-  
Note:- Water is fit for drinking

Lab No.- MCPHL/24/ 1429  
Dated:- 16.04.2024


  
Chemist  
M.C.P.H. Laboratory  
Chandigarh

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh


Endst No. MCPH/24/.....

Dated :-.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh with reference to your letter Endst No. MOH/supdt. Admn/2024/4140 Dated 02.04.2024

  
Headmaster  
Govt. Model High School  
Maloya-II, Chandigarh (U.T.)

  
Chemist  
M.C.P.H. Laboratory  
Chandigarh

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh